

NOTES:

- 1. LADDERS SHALL BE FITTED IN PITS DEEPER THAN 2400 MILLIMETRES
- MATERIAL FOR LADDERS SHALL BE STRUCTURAL GRADE 250 TO AS1204.
- 3. ALL WELDING SHALL CONFORM TO AS 1554 PART 1.
- 4. ALL STRUCTURAL STEEL SHALL BE HOT-DIP GALVANISED AFTER FABRICATION AS SPECIFIED IN AS 1650.

ENGINEERING SERVICES BRANCH

- 6. ALL SHARP EDGES SHALL BE ROUNDED BEFORE GALVANIZING.
- 6. ALL OTHER STEEL COMPONENTS NUTS, BOLTS, WASHERS, ETC. SHALL BE GALVANIZED.
- 7. LADDERS SHALL BE FREE FROM DEFECTS LIABLE TO CAUSE DAMAGE TO THE HANDS.

NOT TO SCALE



STANDARD MCC RUNG LADDER DETAIL

Approved By		Drawing Number	1P 50322
Principal Engineer Infrastructure	Manager Engineering Services	Revision	E
Date Nov, 2010	Date Nov, 2010	Docs Number	