



**NOTES:**

1. TAPE TO BE YELLOW CLASS 1 (AS1906.1) UNLESS LOCAL REGULATIONS SPECIFY OTHERWISE.
2. ALLOW 30 - 50 mm FOR REINSTATEMENT OF EXISTING PAVEMENT
3. STEEL PIPE TO BE MIN. 3mm WALL THICKNESS PAINTED WHITE: 2 COATS GLOSS ENAMEL AND 1 COAT UNDERCOAT LAYER

NOT TO SCALE

**ENGINEERING SERVICES BRANCH**



CITY OF MELBOURNE

**PIPE BOLLARD WITH  
CONCRETE INFILL**

Approved By

Principal Engineer  
Infrastructure

Date Nov, 2010

Manager  
Engineering Services

Date Nov, 2010

Drawing  
Number

1P 50511

Revision

B

Docs  
Number